



CITY COUNCIL STAFF REPORT

DATE: December 3, 2014

CONSENT AGENDA

SUBJECT: REPORT OF ESCALATOR REPAIR AT THE PALM SPRINGS INTERNATIONAL AIRPORT PURSUANT TO PALM SPRINGS MUNICIPAL CODE SECTION 7.04.040.

FROM: David H. Ready, City Manager

BY: AIRPORT

SUMMARY

Pursuant to section 7.04.040 (3) of the Municipal Code, the City Manager exercised his authority to approve the emergency repair Notice To Proceed for the up escalator at the Palm Springs International Airport in the amount of \$31,498.50 with KONE, Inc. on November 20, 2014 to protect the safety of the traveling public at the airport. Section 7.04.040 (4) requires that a written report of the circumstances for emergency purchases in excess of \$25,000 be made to the Council at the next regularly scheduled meeting after the emergency procurement is made.

RECOMMENDATION:

Receive and File.

STAFF ANALYSIS:

Palm Springs International Airport has two outdoor escalators that provide for the safe and efficient movement of passengers up to and down from the Bono Concourse. Both of the escalators are original equipment installed during the construction of the facility in the late 1999. The up escalator to the Bono Concourse ceased running due to damage of steps from failed rider bearings. Due to the long lead time for the special order of these replacement parts, and the approaching busy travel season, it was critical that the part order and repair process commence as expeditiously as possible.


FISCAL IMPACT:

ITEM NO. 26

Funds for this emergency repair were available and encumbered from account 416-6501-56175 for \$31,498.50.



Thomas Nolan,
Executive Director, Airport



David H. Ready, City Manager